

MONTHLY REPORT FOR THE MONTH OF JULY 2019

SUBMITTED BY DISTRICT LEVEL SPECIAL TASK FORCE

The 11th Meeting of District Level Special Task Force was held on 17.07.2019. Sh. Vivek Pandey, Scientist 'B', Chandigarh Pollution Control Committee informed that DLSTF had already conducted the inspections of Sukhna Choe & N-Choe and Municipal Corporation, Chandigarh has been directed to take necessary action. Further, he informed that 02 field visit have also been conducted to check the industries w.r.t. ETP.

Thereafter, the status of all the discharge points of Sukhna Choe and N-Choe were discussed.

STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE

Sr. No.	Point	Status as on September 2018	Action Plan	Present Status
1	Kishangarh Outlet	There was sewage water discharge from the outlet.	STP has been proposed to treat the waste water (Will be commissioned by Nov. 2021)	Plugged
2	Outlet of Village Kishangarh inside Forest Nursery	There was sewage water discharge from the outlet.	Chandigarh Administration will tap the same by 31.03.2019.	Plugged
3	Outlet of Shastri Nagar	There was sewage water discharge.	-	Plugged
4	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	There was sewage water discharge at first outlet of Bapu Dham near bridge on the road connecting IT Park	-	Plugged

5	Second outlet of Bapu Dham Colony (Known as Madrasi Colony)	There was sewage water discharge at second outlet of Bapu Dham colony	Municipal Corporation Chandigarh has stopped all such discharges points and there is no waste water discharge. (For long term CBD will be replaced by RCC pipe and will be completed by 31.12.2019)	Plugged
6	Outlet from back of Gaushala, Industrial Area, Phase-I, Chd.	There was substantial sewage discharge from back of Gaushala, Industrial Area, Phase-I, Chd.	-	Plugged
7	Outlet near CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	There was sewage discharge at the outlet near CTU workshop.	-	Plugged
8	Indl. Area, Phase - I, Colony No. 4.	There was discharge from many outlets from Indl. Area, Phase - I, Colony No. 4.	-	RCC wall to be constructed, tender in process.
9	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase - I, Chandigarh.	In case of Non-operation of pump, waste water directly goes to Sukhna Choe on regular basis.	-	Discharge has been curbed by installing standby Motor

10	Outlet of Village Hallomajra	There was substantial sewage discharge from the outlet of Village Hallomajra.	By 31.01.2019 all the household will be connected to sewer line.	More than 80% connections have been given. Documents of rest 20% are being checked.
11	Village Daria	There was discharge of sewage water from Village Daria	-	Motor has been repaired. Now no sewage is being discharged in Sukhna choe

STATUS OF UNTREATED WASTE WATER DISCHARGE IN N- CHOE

Sr. No.	Point	Status as on September 2018	Action Plan	Present Status
01	Bougainvillea Garden	01 Outlet is still being discharged from MLA Hostel side. However Fresh Water is being discharged.	-	Still fresh water from MLA Hostel is being discharged. The concerned authorities have been intimated for plugging the same.
02	Leisure valley	02 outlets were discharging waste water	One outlet has been plugged and there is little discharge from one outlet, will be plugged by 31.12.2018.	Plugged
03	Near Red Cross (Madhya Marg)	01 outlet was discharging waste water	-	A leakage has been detected at Home Science College Sector 10. The work is to be done by Chd. Admn.
04	Sec 23 near Neuro Psychiatry Hospital	01 outlet discharging waste water	-	Plugged

05	Bal Bhawan Side	Very less discharge	-	Plugged
06	MCM DAV	One outlet of sewage water was being discharged	-	Plugged
07	01 outlet in Beant Memorial	Water logging	This is major work and will be completed by August 2019	-
08	Sector 52 (starting)	Two outlets discharging Sewage Water	The work will be taken care when the work of Beant Memorial Outlet(will be plugged by 31.12.2019)	-
09	Sector 52 (End)	Two outlets discharging Sewage Water	One outlet has been plugged and another outlet will be plugged by 31.12.2019.	-
10	One outlet coming from Sec 51	Sewage Water	-	Already tapped. Now there is no sewage water.
11	Sector 36 Starting point near Central Forensic Science Laboratory	One outlet from CFSL side was discharging in N-choe	-	Plugged
12	Sector 10 Points	One outlet where fresh water was being discharged	-	Plugged
13	Rose Gardens	02 outlets were discharging the waste water	-	Plugged
14	Shanti Kunj Garden	Waste water was being discharged	-	Plugged

15	Sector 23 Traffic Park	Waste water was being discharged	-	Plugged
16	Sector 23 End Point	There are four discharge points sewage water was being discharged from three outlets	-	Plugged
17	Attawa	02 Points were discharging sewage water into N-Choe	-	01 No. has been plugged whereas the source of sewer discharge has to be identified.
18	Sector 53 point near Furniture Market	01 outlet of sewage water was being discharged	-	The work allotted to the agency but this work can only be completed after the strenghtening of main sewer line.
19	Sector 53 point in Gardens of springs	01 outlet of sewage water in huge quantity was being discharged (Adarsh Colony)	-	The deviation work to be done near Adarsh Colony. Estimate for constructing the sump to lift sewgae to the nearest line is in progress.

2. Status of Tenders w.r.t. upgradation of STPs and construction of new STPs

Municipal Corporation, Chandigarh has informed that due to change in Phosphate Concentration for STP Outlets by Hon'ble NGT, they have to retender to include the same in specifications, which will take some time. They are in the process of changing technical specifications w.r.t. phosphate.

3. Status of installation of Flow Meters at Drains

Sh. Rajinder Singh, S.E. Engg. Deptt., Chandigarh Administration informed about the installation of flow meters at drains. He submitted that survey has been done at the respective

points and it is found that there are technical difficulties being faced in installation of flow meter, as there are no definite discharge points. However, he assumed that he will do the needful after consulting the officers of other States for a possible solution.

4. Status of Action taken by Municipal Corporation, Chandigarh regarding non-compliance of existing STPs.

Sh. Vivek Pandey, Scientist 'B' informed that in the month of June out of 05 STPs, 02 STPs are not meeting with the prescribed norms. Sh. Ishwar Dutt Sharma, Executive Engineer, Municipal Corporation Chandigarh informed that due to very old infrastructure at STPs they are facing problem in maintaining the norms, however, they are trying their best to treat the waste water as per the norms. Further he also informed that Maloya STP is operational now.

Sh. Ishwar Dutt Sharma, Executive Engineer, Municipal Corporation Chandigarh informed that due to breakage in line which carries waste water to Diggian STP, presently Diggian STPs is not operational and it will take 2-3 months for repairing of the same. Chairman directed Municipal Corporation, Chandigarh to take necessary steps to repair the same at the earliest.

5. Status of Action Taken by MC, Chandigarh regarding stoppage of untreated discharge of waste water into Choes.

Sh. Ishwar Dutt Sharma, Executive Engineer, Municipal Corporation, Chandigarh informed that they are already in process and most of the points have already been tapped and for the rest process is under progress.

6. Regarding Organisation of Health Camps:

Ms. Shobhna Pathania, Nodal Officer, Health Deptt., UT, Chandigarh has informed that Chandigarh is having good number of dispensaries in villages and regular check up of residents is being done there. However, as per the directions they will conduct health camp on 31st July, 2019.

Further, Sh. Vivek Pandey, Scientist 'B' informed that CPCC is in process to initiate suitable action on non complying industries.