

MONTHLY REPORT FOR THE MONTH OF APRIL 2019

SUBMITTED BY DISTRICT LEVEL SPECIAL TASK FORCE

Sh. Vivek Pandey, Scientist 'B', CPCC met with the Chairman, District Level Special Task Force-cum-District Magistrate, U.T. Chandigarh on 22.04.2019 and briefed him the decision/observations of Executive Committee in their meetings and informed that committee desired that District Level Special Task Force should visit the concerned areas/industries to identify the violators if any.

Accordingly, Chairman, District Level Special Task Force called Ms. Najuk Kumar, IAS, SDM (Central) and informed him about the status and told that team of District Level Special Task Force lead by Ms. Najuk Kumar, IAS, SDM Central will visit N-Choe on 25.04.2019 and Sukhna Choe on 26.04.2019.

Accordingly, above lead by Ms. Najuk Kumar, IAS, DSM Central visited the N-Choe on dated 25.04.2019 from starting point at Bougainvillea garden till N-Choe enters into Punjab area.

During inspection it was found that there were many new points where earlier sewage point is plugged but now again sewage water is being discharged and many places fresh water is being discharged because of leakage/brokage of pipe lines etc.

The detail of points are as given below.

STATUS OF UNTREATED WASTE WATER DISCHARGE IN N- CHOE

Sr. No.	Points	Status as on 25.04.2019
01	Bougainvillea Garden	01 Outlet is still being discharged from MLA Hostel side. However Fresh Water is being discharged.
02	Leisure valley	Now 02 outlets have been plugged.
03	Sector 10 Points	One Outlet where Fresh Water is being discharged.
04	Sector 16 Near red cross (Madhya Marg)	Two Outlets have been plugged but fresh water is being discharged from third outlet.
05	Rose Gardens	Now 02 outlets have been plugged.
06	Shanti Kunj Garden	Now all outlets have been plugged.
07	Sec 23 near Neuro Psychiatry Hospital	Outlet has been plugged.
08	Sector 23 Traffic Park	There are four discharge points. Sewage Water is being discharged from three outlets.
09	Sector 23 End Point	Now all outlets have been plugged.

10	Sector 36 Starting point near Central Forensic Science Laboratory	One outlet from CFSL side is still being discharged in N-Choe and due to some technical snag tertiary treated water line is releasing water into N-Choe .
11	MCM DAV	One outlet of sewage water is being discharged.
12	Attawa	02 points are still being discharged sewage water into N-Choe.
13	Bridge Point near Beant Memorial	One outlet of sewage water from Beant Memorial Side and One outlet of sewage water from Sector 42 Girls College side are still being discharged into Sukhna Choe. Moreover, one pipe leakage is also there in this point.
14	Sector 53 point near Furniture Market	One outlet of sewage water is being discharged.
15	Sector 53 Point in Gardens of Springs	One outlet of sewage water in huge quantity is being discharged (Adarsh Colony).

On asking from officials of Municipal Corporation, Chandigarh regarding the discharge of fresh water into Storm water drainage. It was informed by the officials of Municipal Corporation, Chandigarh that there are numbers of water tanks in houses of Chandigarh and in commercial places and some of them leak sometimes and pipelines carrying fresh water also get damaged at several places sometimes because of which fresh water release into storm water drainage and they further informed that it is designed like that in case of any leakage of fresh water or water from compound of houses, roof of houses, commercial places, open areas water goes to storm water drainage and not in sewer lines.

The team visited Sukhna Choe on 26.04.2019 from the starting point to till exit point of Chandigarh. The details are as given below.

STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE

Sr. No.	Points	Status as on 26.04.2019
1	Kishangarh Outlet	Sump has been made and now they lifted the waste water which is connected with sewer line.
2	Outlet of Village Kishangarh inside Forest Nursery	
3	Outlet of Shastri Nagar	Leakage has been plugged but now there is new point from where waste water is being discharged.

4	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	Leakage has been plugged.
5	Second outlet of Bapu Dham Colony (Known as Madrasi Colony)	Earlier Municipal Corporation has plugged the discharge point and encroachment has been removed but now again some people have again started discharged their waste water into drain.
6	Outlet from back of Gaushala, Industrial Area, Phase-I, Chd.	Now, there is very little discharge.
7	Outlet near CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	Now, due to leakage waste water is being discharged into Sukhna Choe.
8	Indl. Area, Phase - I, Colony No. 4.	Barrier has been damaged because of which some quantity of waste water is being discharged into Sukhna Choe.
9	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase - I, Chandigarh.	Motor was running and now no waste water is being discharged into Sukhna Choe.
10	Outlet of Village Hallomajra	Still sewage water is being discharged from two outlets.
11	Village Daria	The motor which lifts the waste water to sewer line was not functional. Now, waste water is being discharged into Sukhna Choe.
12	Points adjacent to Kali Mata Mandir near Indl. Area Ph-II Chandigarh.	There are four discharge points. Sewage Water is being discharged from three outlets.

Ms. Najuk Kumar, IAS, SDM Central, directed to Municipal Corporation, Chandigarh authorities to take immediate action and all the points should be stopped at the earliest and no sewage water should be discharged into storm water drainage.