

Subject: -Monthly Report for month of January 2019 w.r.t. O.A. No. 138 of 2016 and O.A. No. 139 of 2016 titled Stench Grips Mansa's Sacred Ghaggar River (Suo-Motu case)

The 4th meeting of District Level Special Task Force was held on 08.02.2019. The Chairman, DLSTF asked about the action taken on the decisions taken in the last meeting held on 07.12.2019 from all the concerned departments. Sh. Vivek Pandey, Scientist 'B', CPCC apprised that the action plan has been submitted by the U. T. Chandigarh to the Executing Committee as well as CPCB. However he informed that he has to intimate Executing Committee about the action taken on action plan on monthly basis and sometimes before that but Engg. Deptt., Chandigarh Administration and Municipal Corporation do not reply because of which he is unable to send the information timely. After which concerned deptt. provided the current status as per details given below :

STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE

Sr. No.	Point	Status as on September 2018	Status as on 07.12.2018	Status as on 08.02.19
1	Kishangarh Outlet	There is sewage water discharge from the outlet.	As a short term measure proposal has been submitted to lift the waste water and connect it with sewerage line	STP has been proposed to treat the waste water (Will be commissioned by Nov. 2021)
2	Outlet of Village Kishangarh inside Forest Nursery	There is sewage water discharge from the outlet.	Engineering Department, Chandigarh Administration will tap the same by 31.03.2019.	Work is yet to be done
3	Outlet of Shastri Nagar	There is sewage water discharge.	Sump has already been created	Already plugged
4	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	There is sewage water discharge at first outlet of Bapu Dham near bridge on the road connecting IT Park	Leakage has been plugged	Already done
5	Second outlet of Bapu Dham Colony (Known as Madrasi Colony)	There is sewage water discharge at second outlet of Bapu Dham colony	The slum developers have constructed their toilets on the existing CBD. Matter has now been taken up with Estate Office, U.T. Chandigarh for removal of	Already plugged

			encroachment on the CBD at Bapu Dham Colony, so that flow coming into Choe may be plugged.	
6	Outlet from back of Gaushala, Industrial Area, Phase-I, Chd.	There is substantial sewage discharge from back of Gaushala, Industrial Area, Phase-I, Chd.	Plugged	Already done
7	Outlet near CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	There is sewage discharge at the outlet near CTU workshop.	CTU has plugged the waste water flow. Now there is no waste water discharge.	Already done
8	Indl. Area, Phase - I, Colony No. 4.	There is discharge from many outlets from Indl. Area, Phase - I, Colony No. 4.	Waste water has already been tapped and diverted to sewer line.	Already done
9	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase - I, Chandigarh.	In case of Non-operation of pump, waste water directly goes to Sukhna Choe on regular basis.	New stand by motor has already been installed and now no waste water is being discharged into Sukhna Choe.	Already done
10	Outlet of Village Hallomajra	There is substantial sewage discharge from the outlet of Village Hallomajra.	Around 70% of household have been connected to sewer line and for remaining 30% work is under process. By 31.01.2019 all the household will be connected to sewer line.	Will be done upto 28.02.19 as delay is due to non-availability of ownership documents

11	Village Daria	There is discharge of sewage water from Village Daria	Excess sewage of unauthorised colony in village Daria has been tapped and put in the sump and the same is being pumped into the sewer line.	Already done
----	---------------	---	---	--------------

STATUS OF UNTREATED WASTE WATER DISCHARGE IN N- CHOE

Sr. No.	Point	Status as on September 2018	Status as on 07.12.2018	Status as on 08.02.2019
1	leisure valley	02 outlets are discharging waste water	Outlets have been plugged. Now there is no waste water discharge.	Already done
2	Near red cross (Madhya Marg)	01 outlet discharging waste water	Outlet has been plugged. Now there is no waste water discharge.	Already done
3	Sec 23 near B.D Hospital (Neuro Psychiatry)	01 outlet discharging waste water	Outlet has been plugged. Now there is no waste water discharge.	On inspection some fresh water discharge was found, will be plugged upto 31.03.2019 by repairing/placing the defective pipe.
4	Bal Bhawan side	Very less discharge	Outlet has been plugged. Now there is no waste water discharge.	On inspection some fresh water discharge was found, will be plugged upto 31.03.2019 by repairing/placing the defective pipe.
5	01 outlet in Beant Memorial	Water logging	This is major work and will be completed by August, 2019.	-
6	sector 52 (starting)	Two outlets discharging Sewage Water	The work will be taken care when the work of Sr. No. 2 will be	-

			completed (Will be plugged by 31.12.2019).	
7	sector 52 (End)	Two outlets discharging Sewage Water	One outlet has been plugged and another outlet will be plugged by 31.12.2019.	
8	One outlet coming from Sec 51	Sewage Water	Plugged	Already done

1. Chairman asked whether all the members of the committee were present. It was informed that member from Health Department and Legal Services Authority did not come. Sh. Vivek Pandey, Scientist 'B' CPCC informed that he just received call from Ms. Shobhna Pathania, Nodal Officer, Health Department and she informed that she is suffering from high fever and unable to attend the meeting and later call was also received from Sh. Parmjit Singh, DMS, GMSH-16, Chandigarh who also confirmed the same and also informed that they have organised health camp on 30.01.2019 which was also attended by Justice Pritam Pal, Chairman, Executive Committee. However, Chairman, directed that at least somebody from the department should attend the meeting as this matter is of utmost important and directed direct CPCC will write to the HoDs that the representative of Health department and Legal services Authority have not attended the meeting held on 08.02.19.
2. Chairman directed that joint team consisting of member from CPCC, Municipal Corporation and Engg. Deptt will visit all the points of Sukhna Choe and N-Choe to verify the compliance and to check the status. It was decided that Sukhna Choe will be monitored on 11.02.19 and subsequently N-Choe will be monitored.
3. Chairman directed that all the nodal officer of concerned department will provide immediate reply (e-mail as well as physical copy) to the CPCC as and when asked and regularly submit status report failing which strict action will be taken against the concerned nodal officer.
4. Nodal Officer, Chandigarh Smart City Limited informed that they are in the process of tendering for the upgradation of existing STPs and setting up of new STP and will complete the process as per the schedule of action plan.
5. Sh. Rajinder Singh Ahluwalia, S.E., Engineering Department, Chandigarh Administration informed that they have handed over the STP Dhanas and STP Raipur Khurd to Municipal Corporation, Chandigarh and they have also transferred the two outlets i.e. Daria and Shastri Nagar to Municipal Corporation, Chandigarh. Now henceforth, information in this regard will be provided by Municipal Corporation, Chandigarh.
6. Sh. Vivek Pandey, Scientist 'B', CPCC apprised that the SDO (Bldg.), Estate Office has not given the details of industrial units not obtained sewage connections as discussed in the last meeting. He further informed that letter in this regard has already been sent to the concerned department.